



Standard Meter Installation Specifications

Depth of Service: 48"

Length of Service: Copper up to 150'. Service beyond 150' requires a meter vault.

Type of Service:

1. Copper K Soft Domestic 3/4" or 1"; MUST be Copper Tube Size (CTS)
2. Plastic: Customer will install polyethylene pipe 200 P.S.I. or 250 P.S.I.

For both copper and plastic, if pressure exceeds 150 P.S.I., customer must install pressure reducing valve before meter (300 P.S.I. rating).

METER SIZE	A (Meter Only)	B (Meter with 2 Connections)
5/8" (DN 15 mm)	7 1/2"	12 1/2"
3/4" (DN 20 mm)	9" (230 mm)	14 1/2"
1" (DN 25 mm)	10 3/4" (275 mm)	16 1/4"

Effective August 1st, 2006:

In accordance with the rules and regulations of the Municipal Authority of the City of New Kensington, this drawing applies to all new connections and requested turnoffs.

Municipal Authority of the City of New Kensington
P.O. Box 577
920 Barnes Street
New Kensington, PA 15068
(724) 337-3577